

Unit Certificate



FGW TG8 EZE

www.tuv.com
ID 1900000000

No.: 968/GI 1883.01/23

Grid Integration of Distributed Energy Resources

Certificate Holder	Shenzhen Growatt New Energy Co., 4-13/F, Building A, Sino-German(Europe) Industrial Park, Hangcheng Ave, Bao'an District Shenzhen, Guangdong P.R. China	Manufacturer	see certificate holder
Subject	Grid-Connected PV-Inverter MAX xxKTL3-X2 LV (xx=100, 110, 120, 125, 133) MAX xxKTL3-X2(ID) LV (xx=100, 110, 120, 125, 133) MAX xxKTL3-X LV (xx=100, 110, 120, 125, 133) MAX xxKTL3-X(ID) LV (xx=100, 110, 120, 125, 133)		
Codes and Standards	VDE-AR-N 4110:2018 FGW TG 8:2019 Revision 9	FGW TG 4:2019 Revision 9 FGW TG 3:2018 Revision 25	
Scope and result	The power generating units mentioned above meet the requirements of VDE-AR-N 4110:2018-11. The conformity is declared by following documents: Evaluation Report-No.: 968/GI 1883.01/23, 2023-10-16 Validation Report-No.: 968/GI 1883.00/23, 2023-10-16 Test Report No.: CN23WZF3 001, dated 2023-08-08 The manufacturer has provided proof of certification of the quality management system of his production facility in accordance with ISO 9001 or is subject to production monitoring.		
Specific provisions	The deviations and conditions for conformity according to the evaluation report must be observed. The corresponding conditions and deviations are listed on page 2 and 3 of the certificate.		

Valid until 2028-10-16

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT GI3 V5.0:2021-11 in its actual version, whose results are documented in Report No. 968/GI 1883.01/23 dated 2023-10-16. This certificate is specifically valid for the above mentioned system only. It becomes invalid, if any unapproved changes are implemented without prior assessment/approval by the certification body. Authenticity and validity of this certificate can be verified through the above indicated QR-code or at <http://www.fs-products.com>.

TÜV Rheinland Industrie Service GmbH

Bereich Automation
Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2023-10-16

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Marco Klose

www.fs-products.com
www.tuv.com



TÜVRheinland®
Precisely Right.

Unit Certificate

Nr.: 968/ GI 1883.01/23

Grid Integration of Distributed Energy Resources

Technical data of the PGU:

Typ:	MAX 100KTL3-X2 LV MAX 100KTL3-X2(ID) LV MAX 100KTL3-X LV MAX 100KTL3-X(ID) LV	MAX 110KTL3-X2 LV MAX 110KTL3-X2(ID) LV MAX 110KTL3-X LV MAX 110KTL3-X(ID) LV	MAX 120KTL3-X2 LV MAX 120KTL3-X2(ID) LV MAX 120KTL3-X LV MAX 120KTL3-X(ID) LV
Max. apparent power:	110.0 kVA	121.0 kVA	132.0 kVA
Rated active power:	100.0 kW	110.0 kW	120.0 kW
Max. active power (P ₆₀₀):	110.0 kW	121.0 kW	132.0 kW
Rated current:	167.1 A _{AC}	183.8 A _{AC}	200.5 A _{AC}
Typ:	MAX 125KTL3-X2 LV MAX 125KTL3-X2(ID) LV MAX 125KTL3-X LV MAX 125KTL3-X(ID) LV	MAX 133KTL3-X2 LV MAX 133KTL3-X2(ID) LV MAX 133KTL3-X LV MAX 133KTL3-X(ID) LV	
Max. apparent power:	137.5 kVA	146.3 kVA	
Rated active power:	125.0 kW	133.0 kW	
Max. active power (P ₆₀₀):	137.5 kW	146.3 kW	
Rated current:	208.9 A _{AC}	222.3 A _{AC}	
Further general data valid for all types			
Rated voltage:	3/PE 400 V _{AC}		
Nominal frequency:	50 Hz		
Minimum required short-circuit power (only for type 1 PGU):	N/A		
Software-Version:	V 1.0		

Validated Simulation Model:

Reference name: TUVR_MAX+(100-133)KTL3-X(2)+LV_Encrypted.pfd

MD5 Checksum: 9493f09b46bb30768622561a484cb69f

Simulation platform: DIgSILENT PowerFactory 2023

Unit Certificate

Nr.: 968/ GI 1883.01/23

Grid Integration of Distributed Energy Resources


The following deviations and restrictions apply:

☐ None

☒ The following:

- Separate interfaces for setpoint specifications regarding active power (e.g. grid operator, direct marketer) must be implemented at PGS level (e.g. by PGS-controller) and be evaluated as part of system certification.
- As the unit does not contain a display, this has to be considered on project level. With regard To the requirements of the corresponding grid provider, an appropriate device to check the protection settings has to be provided on demand or should be stored on site.
- The certified product does not provide a test terminal. A connecting terminal plate has to be installed separately, if necessary.

Schematic overview of the PGU:





Unit Certificate

Nr.: 968/ GI 1883.01/23

Grid Integration of Distributed Energy Resources

Schematic overview of the PGU:



Unit Certificate

Nr.: 968/ GI 1883.01/23

Grid Integration of Distributed Energy Resources

Schematic overview of the PGU:

